




LOAD SCHEDULE




1 POWER LAYOUT (GF)
E-3 SCALE: 1:175MTS




2 POWER LAYOUT (2F TO 4F)
E-3 SCALE: 1:175MTS




3 ACU & POWER LAYOUT (5F)
E-3 SCALE: 1:175MTS



4 AUXILIARY LAYOUT (GF)
E-3 SCALE: 1:175MTS



5 FIRE ALARM RISER DIAGRAM
E-3 SCALE: NTS



6 FIRE ALARM INSTALLATION DETAILS
E-3 SCALE: NTS

FIRE ALARM WIRING SCHEDULE			
SYMBOL	WIRING DESCRIPTION	CONDUIT	
S	2 - 1.25 SQ.MM TF WIRE	15 MMØ EMT	
P	2 - 2.0 SQ.MM. TW WIRE	15 MMØ EMT	
SP	2 - 1.25 SQ.MM TF WIRE 2 - 2.0 SQ.MM. TW WIRE	15 MMØ EMT	
2SP	4 - 1.25 SQ.MM TF WIRE 2 - 2.0 SQ.MM. TW WIRE	15 MMØ EMT	

	OWNER VICENTE B. MALANO, Ph.D. ADMINISTRATOR	ARCHITECT/ENGINEER	ENGINEER	PROJECT TITLE REHABILITATION/REPAIR OF BASCO AND TOWER BUILDING		SHEET CONTENT LIGHTING LAYOUT AUXILIARY LAYOUT		DRAWN BY: ANGJ CHECKED BY: GSO DATE:		REVISION		SHEET NO. E-3	
				LOCATION: BRGY. TUKON, BASCO, BATANES									