

LOAD SCHEDULE

PANEL: MAIN DISTRIBUTION PANEL (MEP)									
LOCATION: POWER ROOM									
MAIN 150/1000V, 2P, 22KAIC, BOLT-ON									
SYSTEM: 230V, SINGLE PHASE, 60Hz WITH GROUNDING BUS BAR									
CKT NO	LOAD DESCRIPTION	WIRE SIZE		CONDUIT		CB RATING		LOCATION	
		THINWALL	PCB MB	AT	AF	P	KAIC		
1	DISTRIBUTION PANEL (DP)	2-22MM ² + 1-8.0MM ² (G)	25	75	100	2	22	POWER RM	
2	MAIN EMERGENCY PANEL (MEP)	2-60MM ² + 1-13.0MM ² (G)	50	160	250	2	36	RADAR TRANSMITTER RM	
TOTAL		2-80MM ² + 1-13MM ² (G)	50	175	250	2	50		
FEEDER SIZE COMPUTATION:									
IT = (237.02A X 0.95 D.F.) + 25% (12) = 137.82A									
PROVIDE: 2-30MM ² + 1-13MM ² THINWALL WIRE @ 30MM ² PCB PIPE									
CIRCUIT BREAKER COMPUTATION:									
IT = (237.02A X 0.95 D.F.) + 25% (12A) = 172.00A									
PROVIDE: 1-175AT, 250AF, 2P, 1-PHASE 50KAC, BOLT ON									
TRANSFORMER RATING COMPUTATION:									
KVA = (E X I) / 1000									
= (230V X 154.00A) / 1000									
KVA = 35.43KVA									
PROVIDE:									
37.5KVA, 13.2KV/230V, SINGLE PHASE, 60Hz									
POLE MOUNTED DISTRIBUTION TRANSFORMER									

PANEL: MAIN EMERGENCY PANEL (MEP)															
LOCATION: POWER ROOM															
MAIN 160A/250AF, 2P, 22KAC, BOLT ON															
SYSTEM: 230V, SINGLE PHASE, 60Hz WITH GROUNDING BUS BAR															
CKT. NO	LOAD DESCRIPTION	A	V	VA	WIRE SIZE			CONDUIT		CIRCUITING			LOCATION		
					THINWALL	PCB RM/B	AT	AF	P	KAIC					
1	EMERGENCY PANEL (EP)	80.33	230	18475	2-30MM ² + 1-1.6MM ² (G)	32	100	100	2	22	POWER RM				
2	20A UPS FOR RADAR EMERGENCY PANEL BOARD (REP)	86.86	230	20000	2-22MM ² + 1-8.0MM ² (G)	40	100	100	2	22	RADAR TRANSMITTER RM				
TOTAL		167.28	230	38475	2-50MM ² + 1-13.0MM ² (G)	50	180	250	2	32					
FEEDER SIZE COMPUTATION:										PROVIDE:				30XW 230V SINGLE PHASE 80% P.F. 60HZ	
IT = (167.28A X 0.95 D.F.) + 25% (12) = 177.82A														PANEL MOUNTED DIESEL ENGINE GEN. SET	
PROVIDE: 2-50MM ² + 1-13.0MM ² THINWALL WIRE @ 25MM/60 PCB PIPE															
CIRCUIT BREAKER COMPUTATION:										PROVIDE:				30XW 230V SINGLE PHASE 80% P.F. 60HZ	
IT = (167.28A X 0.95 D.F.) + (12A + 250% (2A) = 151.82A															
PROVIDE: 1-160AT, 250AF, 2P, 1PHASE, 22KAC, BOLT ON															

PANEL: DISTRIBUTION PANEL (DP)		LOCATION: POWER ROOM									
MOUNTING: FLUSH		MAIN 75AT/100AT, 2P, 22KAC BOLT ON									
ENCLOSURE: NEMA 1 GAUGE 16		SYSTEM: 200V, SINGLE PHASE, 60HZ WITH GROUNDING BUS BAR									
CKT NO	LOAD DESCRIPTION	WIRE SIZE		CONDUIT		CB RATING		LOCATION			
		VA	THINWALL	PCB MB	AT	AF	KAIC				
1	LIGHTING OUTLET (CKT NO.3 OF EXISTING PDB)	0.78	180	23.5MM ² + 1.2MM ² (G)	15	20	50	2	10	STOCK RM, PCL PRODUCTS, PRINTERY, QTR, QUARTERS	
2	CONVENIENCE OUTLET (Ø-180W)	8.52	230	1500	23.5MM ² + 1.2MM ² (G)	15	20	50	2	10	STOCK RM, PRINTERY, QUARTERS, RADIO COMM RM
3	CONVENIENCE OUTLET (CKT NO.8 OF EXISTING PDB)	5.46	230	1260	23.5MM ² + 1.2MM ² (G)	15	20	50	2	10	RADAR TOWER LOBBY (GF TO 4TH FLOOR)
4	ACU (CKT NO.9 OF EXISTING PDB)	10.00	230	2300	23.5MM ² + 1.3MM ² (G)	15	30	50	2	10	OLD RADAR BUILDING
5	ACU (CKT NO.10 OF EXISTING PDB)	10.00	230	2300	23.5MM ² + 1.3MM ² (G)	15	30	50	2	10	OLD RADAR BUILDING
6	ACU (CKT NO.11 OF EXISTING PDB)	10.00	230	2300	23.5MM ² + 1.3MM ² (G)	15	30	50	2	10	OLD RADAR BUILDING
7	ACU (CKT NO.12 OF EXISTING PDB)	10.00	230	2300	23.5MM ² + 1.3MM ² (G)	15	30	50	2	10	OLD RADAR BUILDING
8	EXHAUST FAN (CKT NO.14 OF EXISTING PDB)	3.91	230	800	23.5MM ² + 1.2MM ² (G)	15	30	50	2	10	POWER ROOM
9	SPARE	6.92	230	1500	23.5MM ² + 1.2MM ² (G)	15	20	50	2	10	
10	SPARE	6.92	230	1500	23.5MM ² + 1.2MM ² (G)	15	20	50	2	10	
TOTAL		68.74	230	16040	2-22MM ² + 1.8MM ² (G)	25	75	100	2	22	
FEEDER SIZE COMPUTATION:											
IT = (68.74A x 0.95 D.F.) + 25% (10) = 47.83A											
PROVIDE: 2-22MM ² + 1.8MM ² THINWALL WIRE @ 25MM ² PCB PIPE											
CIRCUIT BREAKER COMPUTATION:											
IT = (68.74A x 0.95 D.F.) + 25% (10) = 47.83A											
PROVIDE: 1-75AT, 100AF, 2P, 1PHASE, 22KAC BOLT ON											

PANEL		EMERGENCY PANEL (EP)		LOCATION		POWER ROOM					
MOUNTING		FLUSH		MAIN 100A/100AF 2P 22KAC BOLT ON							
ENCLOSURE		FRANK 1 (GRADE II)		SYSTEM 230V SINGLE PHASE 60Hz WITH GROUNDING BUS BAR							
CKT NO	LOAD DESCRIPTION	A	V	VA	WIRE SIZE		CONDUIT	CB RATING		LOCATION	
					THINWALL	PCB MB		AT	AF		P
1	EMERGENCY OUTLET (B-180W) (NEW LED BULB)	1.33	230	306	2-5.5MM ² + 1-2.0MM ² (G)	15	20	50	2	10	MAN STAIR
2	EMERGENCY OUTLET (B-180W) (NEW LED BULB)	3.28	230	749	2-5.5MM ² + 1-2.0MM ² (G)	15	20	50	2	10	HALLWAY LOBBY (GF-5F) WIRE CHASE
3	EMERGENCY OUTLET (B-180W) (NEW LED BULB)	0.87	230	200	2-3.5MM ² + 1-2.0MM ² (G)	15	20	50	2	10	ROOF DECK
4	EMERGENCY OUTLET (CKT NO.1 OF EXISTING PDB)	2.00	230	460	2-3.5MM ² + 1-2.0MM ² (G)	15	20	50	2	10	PASSAGE WAY & POWER ROOM (OLD RADAR BLDG)
5	EMERGENCY OUTLET (CKT NO.2 OF EXISTING PDB)	1.30	230	300	2-3.5MM ² + 1-2.0MM ² (G)	15	20	50	2	10	PASSAGE WAY & POWER ROOM (OLD RADAR BLDG)
6	EMERGENCY OUTLET (B-180W)	7.04	230	1620	2-3.5MM ² + 1-2.0MM ² (G)	15	20	50	2	10	RADIO RM, RADIO STN RM, WAITING AREA, OBSERVATION AREA
7	EMERGENCY OUTLET (CKT NO.5 OF EXISTING PDB)	5.48	230	1260	2-3.5MM ² + 1-2.0MM ² (G)	15	20	50	2	10	RADIO RM, RADIO STN RM, WAITING AREA, OLD RADAR BLDG
8	EMERGENCY OUTLET (CKT NO.6 OF EXISTING PDB)	5.48	230	1260	2-3.5MM ² + 1-2.0MM ² (G)	15	20	50	2	10	RADIO RM, RADIO STN RM, WAITING AREA, OLD RADAR BLDG
9	EMERGENCY OUTLET (CKT NO.7 OF EXISTING PDB)	0.40	230	200	2-3.5MM ² + 1-2.0MM ² (G)	15	20	50	2	10	POWER ROOM, POLY PRODUCTS RM, OBSERVATION AREA
10	EMERGENCY OUTLET (CKT NO.8 OF EXISTING PDB)	12.00	230	2760	2-5.5MM ² + 1-3.5MM ² (G)	15	30	50	2	10	RADIO COMM RM
11	EMERGENCY OUTLET (B-180W) (NEW LED BULB)	230	230	2760	2-5.5MM ² + 1-3.5MM ² (G)	15	30	50	2	10	STIFF FLOOR
12	EMERGENCY OUTLET (B-180W) (NEW LED BULB)	12.00	230	2760	2-5.5MM ² + 1-3.5MM ² (G)	15	30	50	2	10	STIFF FLOOR
13	EMERGENCY OUTLET (B-180W) (NEW LED BULB)	230	230	2760	2-5.5MM ² + 1-3.5MM ² (G)	15	30	50	2	10	STIFF FLOOR
14	EMERGENCY OUTLET (B-180W) (NEW LED BULB)	8.52	230	1950	2-5.5MM ² + 1-2.0MM ² (G)	15	20	50	2	10	STIFF FLOOR
15	EMERGENCY OUTLET (B-180W) (NEW LED BULB)	8.52	230	1950	2-5.5MM ² + 1-2.0MM ² (G)	15	20	50	2	10	POWER RM
16	EMERGENCY OUTLET (B-180W) (NEW LED BULB)	8.52	230	1950	2-5.5MM ² + 1-2.0MM ² (G)	15	20	50	2	10	POWER RM
TOTAL		80.33	230	19475	2-30MM ² + 1-1.6MM ²	32	100	100	2	22	
FEEDER SIZE COMPUTATION:											
IT = (69.74A x 0.95 D.F.) + 25% (10) = 47.83A											
PROVIDE: 2-30MM ² + 1-1.6MM ² THINWALL WIRE @ 32MM ² PCB PIPE											
CIRCUIT BREAKER COMPUTATION:											
IT = (69.74A x 0.95 D.F.) + 25% (10) = 47.83A											
PROVIDE: 1-100AT, 100AF, 2P, 1PHASE, 22KAC, BOLT ON											

NOTE: CKT NO. 10 & 11 ARE IN MANUAL TRANSFER SWITCH (MTS)
CKT NO. 12 & 13 ARE IN MANUAL TRANSFER SWITCH (MTS)

FEEDER SIZE COMPUTATION:
IT = (69.74A x 0.95 D.F.) + 25% (10) = 47.83A
PROVIDE: 2-30MM² + 1-1.6MM² THINWALL WIRE @ 32MM² PCB PIPE
CIRCUIT BREAKER COMPUTATION:
IT = (69.74A x 0.95 D.F.) + 25% (10) = 47.83A
PROVIDE: 1-100AT, 100AF, 2P, 1PHASE, 22KAC, BOLT ON

	OWNER		ARCHITECT/ENGINEER		ENGINEER		PROJECT TITLE		SHEET CONTENT		REVISION		SHEET NO.		
	VICENTE B. MALANO, Ph.D. ADMINISTRATOR						REHABILITATION/REPAIR OF BASCO AND TOWER BUILDING		LOAD SCHEDULE		DATE:		E-4		
		LICENSE NO.		VALID UNTIL		PTR NO.		DATE ISSUED		DRAWN BY		DATE			
		PTR NO.		DATE ISSUED		PTR NO.		DATE ISSUED		CHECKED BY		DATE			
										ANGJ					
										DATE					