



21 April 2026

SUPPLEMENTAL BID BULLETIN
ADDENDUM NO. 2026-31-01

Subject: Supply, Delivery, Installation, Testing and Commissioning of three (3) units brand new 10kVA Uninterruptible Power Supply (UPS), including their accessories and components (Reference: PR 2025-11-0754 | IB 2026-31)

This Bid Bulletin is being issued to all prospective bidders to clarify, amend, and/or modify certain provisions in the Bidding Documents and to answer written queries and clarificatory questions during the pre-bid conference by prospective bidders, to wit:

Queries from: **One Commerce Int'l Corp.**

Queries	Answers
<p>Terms of Reference “within 90 calendar days from receipt of the Notice to Proceed (NTP)”</p> <p>Due to the current global issue that affects the majority of the raw materials and transportation, we would like to ask if we can request for 150 calendar days from receipt of NTP.</p>	<p>The request to extend the delivery period from ninety (90) to one hundred fifty (150) calendar days from receipt of the Notice to Proceed (NTP) cannot be accommodated, as the project requires immediate implementation and the required delivery timeline shall remain unchanged.</p> <p>However, time extensions may be considered during contract implementation based on merit, subject to evaluation and approval, in accordance with applicable laws, rules, and regulations.</p>
<p>Terms of Reference: Warranty and Support B. Quarterly Preventive Maintenance Visits to check and optimize UPS performance.</p> <p>Is the Quarterly PMS good for 3 years? Could we request this to be semi-annual PMS.</p>	<p>Preventive maintenance shall be conducted quarterly for three years</p>
<p>BDS and Checklist is contradictory when it comes to applicability of Bid Securing Declaration, which one should be followed?</p>	<p>The Bid Securing Declaration remains an acceptable and valid form of bid security. The “Not Applicable” indication in the Checklist pertains solely to the non-specification of a bid security amount and does not preclude, restrict, or invalidate the submission of a Bid Securing Declaration by the bidder.</p>

Queries from: **Unison Computer Systems, Inc..**

Queries	Answers
<p>Under the Terms of Reference (TOR), item letter F, the bidder must have the following personnel employed for at least two (2) years, meeting the required qualifications and experience. Relevant documents including CVs, training certificates, PRC licenses, and Certificates of Employment, must be submitted.</p> <p>We respectfully request that the requirement for the word “employed” be relaxed. Instead, the Bidder must have access to or engage at least One (1) Certified UPS Engineer with</p>	<p>For purposes of compliance with Item F of the Terms of Reference, the requirement for personnel to be “employed” by the Bidder is hereby clarified to include personnel who are directly engaged on a consultancy or contractual basis.</p> <p>Accordingly, the Bidder may present qualified personnel who are not formally employed, provided that such</p>

“tracking the sky...helping the country”

<p>specialized training from the Manufacturer of the UPS brand being offered. Please kindly consider compliance even if the Certified Engineer is not directly employed by the Bidder, provided that the Engineer has successfully completed the manufacturer's technical training course covering installation and troubleshooting of the Uninterruptible Power Supply (UPS). And at least One (1) Product Manager. (Must attach the Technical Training Certificate issued by the Manufacturer as proof of compliance.)</p>	<p>engagement is evidenced by a duly executed agreement, and that all prescribed qualifications, certifications, and response time requirements under the Terms of Reference are fully met.</p>
<p>Registered Electrical Engineer – Oversees UPS installation (Attach PRC ID & Certificate of Employment)</p> <p>We may request to relax and to consider at least the bidder had a consultant of a Registered Electrical Engineer - Oversees UPS installation (Attach PRC ID and Certificate of Employment) even if not directly employed by the bidder.</p>	<p>The requirement for a Registered Electrical Engineer to oversee UPS installation is hereby clarified to include professionals who are not directly employed by the Bidder but are engaged on a consultancy or contractual basis.</p> <p>Such engagement must be supported by a duly executed agreement. The consultant shall possess a valid PRC ID, and all prescribed qualifications and response time requirements under the Terms of Reference must be fully complied with.</p>
<p>Registered Master Electrician – Ensures compliance with electrical standards (Attach PRC ID & Certificate of Employment)</p> <p>We may request to relax and to consider at least the bidder had a consultant of a Registered Master Electrician - Oversees UPS installation (Attach PRC ID and Certificate of Employment) even if not directly employed by the bidder.</p>	<p>The requirement for a Registered Master Electrician to ensure compliance with electrical standards is hereby clarified to include professionals who are not directly employed by the Bidder but are engaged on a consultancy or contractual basis.</p> <p>Such engagement must be supported by a duly executed agreement. The consultant shall possess a valid PRC ID, and all prescribed qualifications and response time requirements under the Terms of Reference must be fully complied with.</p>
<p>Safety Officer – Oversees project safety (Attach DOLE-accredited Safety Training Certificate)</p> <p>Must have directly employed by the bidder.</p>	<p>You may proceed with direct engagement even if not employed, as a consultant, provided that the agreement is duly signed and all specified response time requirements are met</p>

Queries from: **Automation Specialists and Power Exponents, Inc.**

Queries	Answers
<p>Sought clarification on the electrical requirements in NAIA, particularly on whether a breaker-type configuration may be used instead of the specified rack-mounted bypass.</p>	<p>The technical specifications outlined in the Terms of Reference (TOR) represent the minimum requirements of the Project. Accordingly, prospective bidders may propose alternative solutions in their respective proposals, provided that such alternatives are fully compliant and responsive to the specific project requirements and offer clear advantages to the government.</p>

"tracking the sky...helping the country"

Science Garden Compound, Senator Miriam Defensor Santiago Ave.,
Brgy. Central, Quezon City, Metro Manila, Philippines 1100

Tel. No. (02) 8284-0800
Website: <http://bagong.pagasa.dost.gov.ph>

Sought clarification on the preventive maintenance requirements, specifically on the frequency of preventive maintenance to be conducted per year.	Preventive maintenance shall be conducted quarterly for three years
--	---

Modification to TOR

Query	Answers
<p>Batteries & Runtime: Run Time</p> <p>Clarification to the required battery runtime specification</p>	<p>Batteries & Runtime: Run Time</p> <p>The specification for the battery runtime was revised.</p> <p>From: 11 mins To: 25 mins at full load</p>

This shall form an integral part of the Bid Documents.

For guidance and information of all participating bidders.

Sgd.
SHIRLEY J. DAVID, MoS
Chairperson, PAGASA-BAC



"tracking the sky...helping the country"

Science Garden Compound, Senator Miriam Defensor Santiago Ave.,
Brgy. Central, Quezon City, Metro Manila, Philippines 1100

Tel. No. (02) 8284-0800
Website: <http://bagong.pagasa.dost.gov.ph>