

Republic of the Philippines

DEPARTMENT OF SCIENCE AND TECHNOLOGY

Philippine Atmospheric, Geophysical and Astronomical Services Administration (PAGASA)

23 November 2022

SUPPLEMENTAL BID BULLETIN
ADDENDUM NO. 2022-029-01 Re bid

Subject: <u>Supply, Delivery, Installation, Testing and Commissioning of the Amihan and Habagat Conference</u>
Room Audio Video System Upgrade and Room Rehabilitations – Re bid

(PR No. 2022-09-0769 / IB No. 2022-029 Re bid)

This Bid Bulletin is being issued to all prospective bidders to clarify, amend and/or modify certain provisions in the Bidding Documents and to answer the written clarificatory questions submitted by prospective bidders, to wit:

Query from **IMATECH CORPORATION**

Question(s)	PAGASA BAC Answer(s)
 I would like to inquire if you could send us the design and dimensions of your preferred conference table and chairs? 	Table measurement is 5m x 3m. design for approval prior to delivery.
Window Blinds – is this supply only because there is no statement for the installation.	Window blinds will be installed
3. THHN AWG #10 wire, Cat 6 Indoor UTP cable, Din Rail 30A breaker system with housing and 30A volt-on breaker – are these the materials that will be used for installation?	This will be used for the electrical power system source and protection of the system in the rack.

Clarificatory questions during the pre-bid conference by prospective bidders:

Question(s)	PAGASA BAC Answer(s)
TOR – page 4 Item 2.2 Line Source Loudspeaker Is this for built-in sub-woofer only?	No. This is not for built-in sub-woofer only.
TOR – page 9 Line 1.4 Live Streaming and Production Software – 2 units	Yes. 2 software packages, 1 for Amihan conference Room and 1 for Habagat Conference Room
TOR – page 10 Must have Live Production and Streaming Software	
Does it mean separate quantity of deliverables?	

This shall form an integral part of the Bid Documents.

For guidance and information of all participating bidders.

Sgd BONIFACIO G. PAJUELAS, Ph.D.

Chairperson, PAGASA-BAC

"tracking the sky...helping the country"

Science Garden Compound, BIR Road, Brgy. Central, Quezon City,

Metro Manila, Philippines 1100

Postal Address: P.O. Box 3278 Manila

Tel. Nos. (632) 929 48 65; (632) 434 90 40

Fax: (632) 929 48 65

Website: http://bagong.pagasa.dost.gov.ph