



Republic of the Philippines

DEPARTMENT OF SCIENCE AND TECHNOLOGY

Philippine Atmospheric, Geophysical and Astronomical Services

Administration (PAGASA)

26 October 2022

SUPPLEMENTAL BID BULLETIN

ADDENDUM NO. 2022-032-01

Subject: Supply, Delivery, Installation and Commissioning of Five (5) Air-Conditioning Units (ACU) for ICT Server Room and Old Satellite Room

This Bid Bulletin is being issued to all prospective bidders to clarify, amend and/or modify certain provisions in the Bidding Documents and to answer the written clarificatory questions submitted by prospective bidders, to wit:

Query from **ACMI Office Systems Philippines, Inc.**

Question(s)	PAGASA BAC Answer(s)
1. Will the five (5) existing units be dismantled and replaced with the new units? Or will the five (5) units be an additional to supplement the existing air conditioners?	Old units will be dismantled and replaced by new units.
a. If it this project will be a replacement of existing air conditioners, may we inquire if we may use the existing power supply lines (feeder lines) from the main panel to the service breaker? b. If this project will be an additional to the existing air conditioners, may we inquire if the laying of the feeder line from the main panel to the service breaker be part of our deliverables as well? If yes, may we know what type of conduit will you require?	Yes, you may use the existing power supply lines (feeder lines) from the main panel to the service breaker but you need to provide new breaker. Please see BOQ for the project. Be sure to coordinate with PAGASA electrical engineer for their approval. No need, but you have to provide new outdoor and indoor breaker or see the BOQ,
2. May we conduct a site inspection to see the current site conditions? May we request for a contact person and his/her contact number to coordinate with?	Yes, you may conduct site inspection, you may contact Rolymer Canillo with cp no. 0905 270 4140 or Eric Valenzuela with cp no. 0918 437 4635
3. We would like to inquire if authorized dealers and installers may join the bidding. Based on the TOR section 3.2.2, only exclusive distributors may join the bidding. We would like to request that the bidding be open to authorized dealers and installers as well, as not all brands have exclusive distributors.	Yes, we will allow authorized dealers and installers
4. Should your office need assurance for the availability of spare parts, may we request that you will require a certificate of availability of spare parts instead from the bidder/brand.	Yes, we will require a certificate of availability of spare parts

"tracking the sky...helping the country"

<p>5. For PVC drain lines, may we tap to the existing provisions should this project be a replacement of the existing air conditioners; or will we need to re-do the entire drain system for the new air conditioners?</p>	<p>Yes, you may use the provision as in hole in the wall but you need to replace the old ones (PVC, etc).</p>
<p>a. If we are to re-do the entire drain system, may we know what size of drain pipe will you require?</p>	<p>You may use the same size of the old pipe based on your site inspection or see the BOQ</p>
<p>6. Under Section 3.0 Qualification of Manufacturer and Bidder, may we clarify that the brand of air conditioner must have been locally available in the Philippine market for at least 5 years?</p>	<p>Yes, brand of air conditioner must have been locally available in the Philippine market for at least 5 years</p>

This shall form an integral part of the Bid Documents.

For guidance and information of all participating bidders.

SGD.
BONIFACIO G. PAJUELAS, Ph.D.
Chairperson, PAGASA-BAC